



“जल संचय-जीवन संचय”

फैवरा नं०-01382-222219

फैवरा नं०-01382-222219

कार्यालय अधिशासी अभियन्ता, उत्तराखण्ड जल संस्थान

बद्रीनाथ मार्ग, नियर बुद्ध पार्क, कोटद्वार (पौड़ी गढ़वाल)

Email ID:- ujs_eekotdwar@rediffmail.com/ujsseekotdwar@gmail.com



पत्रांक-3847 /

प्रभात पत्र

/ 2025-26

दिनांक: 20/02/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.01/UJS?SLWQTML/2025-26


Dated: 05-02-2026

It is certified that an inspection team headed by **Mr. Kuldeep, Chemist Sub-Divisional Level Water Quality Testing & Monitoring Laboratory** Uttarakhand Jal Sansthan, Kotdwar inspected the Gyanvriksh School , Gharat Road Kotdwar, Garhwal. on 02-02-2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **01/UJS?SLWQTML/2025-26 dated 5th of February 2026** (PHED Lab) certified that the **Gyanvriksh has safe drinking water facilities for the students and members of staff of the institution.** School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 04-02-2027


Executive Engineer
(Abhishek Kumar Verma)
Executive Engineer
Uttarakhand Jal sansthan
Kotdwar

To,
Gyanvriksh
Gharat Road, Padampur Sukharo
Kotdwar.


Principal
Gyanvriksh
Padampur Sukharo
Kotdwar (Uttarakhand)


Manager
Gyanvriksh
Padampur Sukharo
Kotdwar (Uttarakhand)



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Kotdwar

Ph (O): 01382 - 222219, E-mail: ujseekotdwar@gmail.com

Test Report ID: 01/UJS/SLWQTML/2025-26

Dated: 05/02/2026

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Parshant Kukreti Manager Gyanvirksh School				
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Gyanvirksh School		
Reference Sample Identification: & Payment Receipt No.:	SDWQTML/UJSK/JAN/26-001 O-KD/3207, KD 17041882 (02/02/2026)		Date of Start of Analysis: 02/02/2026		
Date and Time of Sample Received: 02/02/26 & 11:00AM	Sample Collected by:		Customer		

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.05	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/L	71.5	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	0.59	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/L	30	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO ₃), mg/L	38	200	600	IS 3025 Pt-21: 2002
6.	Chloride, mg/l	19.99	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	15.23	75	200	IS 3025 Pt-40 : 2019
8.	Magnesium (as Mg), mg/L	4.37	30	100	APHA 23rd Ed.-3500-Mg B 2017
9.	Colour, Hazen	Less than 05	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012
12.	Iron (As Fe)	0.01	1	No Relaxation	UV-Vis Spectrophotometer
(B.) Biological Parameters					
13.	E-Coli	Absent	Absent	Absent	MPN
14.	Total Coliform	Absent	Absent	Absent	MPN

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Sub-Divisional Level
Water Quality Testing
& Monitoring Laboratory
Uttarakhand Jal Sansthan (Kotdwar)

अपर सहायक अभियन्ता
उत्तराखण्ड जल संस्थान
रिगिडी (कोटद्वार)

Principal
Gyanvirksh
Padampur Sukhar
Kotdwar (Uttarakhand)

सहायक अभियन्ता
उत्तराखण्ड जल संस्थान
रिगिडी (कोटद्वार)
Manager
Gyanvirksh
Kotdwar

1. The results listed refer only to tested sample and not for general purpose.
2. This certificate is not to be reproduced wholly or in parts promotional or for any other purpose without the authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of this certificate, unless otherwise agreed with customer.